

**Minimum Man Power requirement for Operation and Non Comprehensive Maintenance of Diesel Generator Sets and Connected works**

Sl. No.	Designation	No. of persons	Qualification	Minimum Experience (No. of years)
1	Shift Engineer	2	Diploma in Electrical /Mechanical Engineering	Should have minimum 5 years experience in operation and maintenance of Diesel Generator Sets with "C" license.
2	Shift Technician	3+1	ITI - Electrician	Should have minimum 5 years experience in operation and maintenance of Diesel Generator Sets

**Note :**

(i)The above man power is minimum requirement for routine operation and maintenance of D.G system. In case of annual Non Comprehensive maintenance, major Break downs, Emergency situations, etc. contractor has to provide required manpower, tools, tackles, etc to full fill the contractual requirement. If Contractor feels that the above minimum manpower is not adequate for routine operation and maintenance of D.G system, the contractor shall engage more manpower with in quoted price.

(ii) The O&M is on round the clock service on Seven days per week.

**Payment:**

(iii)The payment will be made on quarterly basis on submission of bills along with all relevant details / including particulars of attendance, EPF, ESI remittance and other statutory provisions. The attendance particulars are subject to verification by TICEL IBMS reports / records.

(iv)In case the services are not upto the mark (or) inadequate manpower are provided and corrective actions are not taken within Seven days a penalty equal to One month of O&M charges will be levied as decided by TICEL.